



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOVAD/2021/00012331
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOVAD/2021/00012331/R1

Date: 04/04/2024

Building Occupancy/Category: Educational (non-residential)

To,

GURUJI SHRI SANDIPANI EDUCATION TRUST

American school of Baroda and Hostel Ajwa nimeta road, sayajipura old survey no.46/1 new survey no:-46/1/A and 46//1/K/ PAIKI Vadodara Vadodara MC VUDA 390019

Fire Region: Vadodara RFO

Mobile No: 9275120396 Email ID: info@asobaroda.org

This has reference to your Application No. **2024/00049430** dated 28/02/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise **American school of Baroda and Hostel (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: old.46/1 new-46/1/A and 46/1/K PAIKI
4. Village Name: Vadodara
5. Name of Block(s): 1

The building/premise was inspected on **04/04/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **04/04/2024**
2. Six monthly inspection was done on **04/04/2024**

The Fire Safety Certificate is renewed for a period of **two (2) years** upto **04/04/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

AMERICAN SCHOOL OF BARODA

Dilipbhai Motibhai Patel
Principal,
American School of Baroda



Digitally Verified

Digitally verified by: Dilipbhai Motibhai Patel
Fire Safety Officer - Specialist (FSO-S)
2021/000337

Date: 04/04/2024
Time: 10:51 AM



FSCA/O/RFOVAD/2021/00012331/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.